



**NOTES:**

- 1.- IN ORDER TO REDUCE THE FINISHED THICKNESS IT IS RECOMMENDED TO PLACE THE STEEL BARS INSIDE OF PANEL W STRUCTURE, BETWEEN THE FOAM AND THE MESH.
- 2.- THE ADDITIONAL REINFORCING STEEL BARS SHOULD BE FIXED WITH TIE WIRE OR STAPLES.
- 3.- THE STEEL BAR # 3 GRADE 60 HAS A DIAMETER OF 3/8" AND A Fy= 60000 psi.
- 4.- THE STEEL BAR # 2 GRADE 85 HAS A DIAMETER OF 1/4" AND A Fy= 85000 psi.
- 5.- SPECIFICATIONS FROM A.C.I. 318-02.

**USA**  
18851 N.E. 29th Avenue  
Suite 700  
Aventura, Florida 33180  
P: (888) 9.PANELW (726359)  
▶ [www.panelw.com](http://www.panelw.com)

**MEXICO**  
Av. Vallarta 5305  
Col. Real Vallarta, C.P. 45020  
Zapopan, Jalisco  
T: +52 (33) 3134.5588

AUTHORIZED DEALER